



AGGREGATE ANALYSIS

GEOTECHNICAL & MATERIALS  
ENGINEERING, TESTING & INSPECTION  
P.O. BOX 15732 • TAMPA, FLORIDA 33684 • 813/872-7821 CA No. 1450

PROJECT: Product Check  
53<sup>rd</sup> Yard - Stockpile

PROJECT NO: 1610.23.1

CLIENT: Transcor

DATE: 2/5/2025

SAMPLE LOCATION: Stockpile

SAMPLE DESCRIPTION: Crushed Concrete (No. 57 Stone)

<u>Sieve Number</u>	<u>Percent Passing</u>	<u>FDOT Specifications Section 901-1.4</u>
1 1/2"	100	100
1"	91	95-100
3/4"	65	---
1/2"	22	25-60
3/8"	9	---
No. 4	8	0-10
No. 8	7	0-5

FINENESS MODULUS: 7.11


DATE SAMPLED: 1/29/2025

DATE RECEIVED: 1/29/2025

DATE TESTED: 2/5/2025

SAMPLED BY: MD

TESTED BY: MD



*Connie A. Johnson-Gearhart*  
**CONNIE A. JOHNSON-GEARHART, P.E.** 2/5/25  
Florida License No. 69013